

# WATER QUALITY TABLE

## REGULATED

Volatile Organic Contaminants	Date Tested	Units	MCL	MCLG	Detected Level	Range	Violation	Major Sources
Total Trihalomethane	2009	ppb	80.0	NA	7.0	2.8 - 7.0	No	By-product of drinking water chlorination
Total Haloacetic Acid		ppb	60	NA	7.7	ND - 7.7		Drinking water chlorination
Ethylbenzene*	2009	ppb	700	700	1.8	ND - 1.8	No	Leaks and spills from gasoline and petroleum storage tanks
Toluene*	2009	ppb	1 ppm	1 ppm	8.6 ppb	ND - 8.6	No	Leaks and spills from gasoline and petroleum storage tanks
Xylenes* (total)	2009	ppb	10 ppm	10 ppm	10.5 ppb	ND - 10.5	No	Leaks and spills from gasoline and petroleum storage tanks

Inorganic Contaminants	Date Tested	# of Sample Sites	AL	MCLG	90th Percentile	# of sites found above the AL	Violation	Major Sources
Copper units ppm	8/2008	20	1.3	1.3	0.3	0	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead units ppb	8/2008	20	15	0	.003	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

	Date Tested	Units	MCL	MCLG	Detected Level	Range	Violation	Major Sources
Perchlorate	9/14/09	ppb	2.0	NA	.24	.18 - .24	No	Blasting, fireworks, military munitions, disinfection by-product
Fluoride	9/14/09	ppm	4	4	.11	.11	No	Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Nitrate	2009	ppm	10	10	1.83	0.26 - 1.83	No	Run-off from fertilizer use;
Nitrite	9/8/09	ppm	1	1	<0.05	<0.05	No	Leaching from septic tanks, sewage; Erosion of natural deposits

	Date	# of QTR Samples	Monthly Avg. ppm	MRDL	Det. Level	Range	Violation	Major Sources
Chlorine ppm	2009	27	.25	4	.65	.15 - .65	No	Water additive used to control microbes

## UNREGULATED

Volatile Organic Contaminants	Date Tested	Units	MCL	MCLG	Detected Level	Range	Violation	Major Sources
Methyl-tertiary-butyl ether <sup>1</sup>		ppb	NA	NA	ND	ND	No	Gasoline additive
Bromodichloromethane <sup>1</sup>		ppb	NA	NA	ND	ND	No	By-product of drinking water chlorination

Inorganic Contaminants	Date Tested	Units	MCL	MCLG	Detected Level	Range	Violation	Major Sources
Sodium	2009	ppm	NA	NA	32.0	20.3 - 32.0	No	Erosion of natural deposits
Sulfate	5/11/09	ppm	NA	NA	18.9	12.2 - 18.9	No	Erosion of natural deposits

Radioactive Contaminants	Date Tested	Units	MCL	MCLG	Detected Level	Range	Violation	Major Sources
Alpha emitters	9/14/09	pCi/L	15	0	.36	ND - .36	No	Erosion of natural deposits

### Water Quality Table Footnotes

<sup>1</sup>These are unregulated contaminants. Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining their occurrence in drinking water and whether future regulation is warranted.

\*Samples contaminated during painting of new filtration plant. Subsequent sample reported no detection.

### Key to Table

AL = Action Level  
MCL = Maximum Contaminant Level  
MCLG = Maximum Contaminant Level Goal  
pCi/L = picocuries per liter (a measure of radioactivity)  
ppm = part per million, or milligrams per liter (mg/L)  
ppb = parts per billion, or micrograms per liter (ug/L)  
NA = not applicable  
ND = none detected  
MRDL = Maximum Residual Disinfection Level  
MRDLG = Maximum Residual Disinfection Level Goal

BULK RATE  
CAR-RT SORT  
U.S. POSTAGE  
PAID  
RAYNHAM, MA 02767  
PERMIT NO. 43



# North Raynham Water District

Raynham, MA

PWSID # 4245002

## 2009 Annual Water-Quality Report

VISIT US @  
[WWW.NRWD.ORG](http://WWW.NRWD.ORG)

North Raynham Water District  
P.O. Box 1  
Raynham, MA 02767

This brochure explains how drinking water provided by North Raynham Water District is of the highest quality. Included is a listing of results from water quality tests as well as an explanation of where our water comes from and tips on how to interpret the data. We're proud to share our results with you. Please read them carefully.

*We are proud to report that the water provided by NORTH RAYNHAM WATER DISTRICT meets or exceeds established water-quality standards.*

In 2003 the Department of Environmental Protection completed the Source Water Assessment and Protection (SWAP) Program Report for The North Raynham Water District.

### What is SWAP?

The Source Water Assessment and Protection (SWAP) Program, established under the Federal Safe Drinking Water Act, requires every state to:

- inventory land uses within the recharge areas of all public water supply sources;
- to assess the susceptibility of public water supplies to potential contamination from these land uses by microbiological pathogens and chemicals; and
- publicize the results to provide support for improved protection.

### What is system ranking?

A susceptibility ranking of **high** was assigned to this system using the information collected during the assessment by the DEP.

### Where Can I See The SWAP Report?

The complete SWAP report is available at the North Raynham Water District Office located at 80 Baker Road, The Town of Raynham Board of Health and the Board of Selectmen's offices located at 558 South Main Street, Raynham, Massachusetts. For more information, call Arthur S. Bendinelli with the North Raynham Water District at (508) 824-0520 or at <http://www.mass.gov/dep/water/swapreps.htm>.

### Project Update 2009

#### Arrowhead Lane Water Filtration Plant (Formerly King Philip Filtration Plant)

Construction of the new filtration plant is complete. The project was on time and under budget. Testing and start-up of the facility went better than anticipated. The filtration plant has been on-line since June of 2009 and during that six-month period has produced 45,655,000 gallons of high quality water that are void of the minerals iron and manganese. To prevent confusion for the police and fire department when responding to any emergencies, the name of the facility, because it was located on Arrowhead Lane was changed. The District already has another facility located on King Philip Street.

### How to Read This Table

The following table lists all the drinking water contaminants that we detected during the 2009 calendar year or during the most recent sampling period within the past five years. These were the only contaminants detected in all the monitoring required by the state. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2009. The state requires the district to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Our system has had our monitoring requirements for synthetic organic compounds (SOCs) and Inorganic Compounds (IOCs) reduced by Mass DEP to less than once per year because the source is not at risk of contamination. The last SOC samples were collected on 6/4 & 11/5/2007 and the last IOC samples were collected on 6/5/2006. All samples results are free of these contaminants.

#### Maximum Contaminant Level or MCL

The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible using the best available treatment technology.

#### Maximum Contaminant Level Goal or MCLG

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

#### Detected Level

The highest level detected of a contaminant for comparison against the acceptance levels for each parameter. These levels could be the highest single measurement, or an average of values depending on the contaminant.

#### Action Level (AL)

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

#### Range

The range of all values for samples tested for each contaminant.

*The data presented in this report is from the most recent testing done in accordance with regulations.*

*For more information, call Arthur S. Bendinelli with North Raynham Water District at (508) 824-0520 or [abendinelli@town.raynham.ma.us](mailto:abendinelli@town.raynham.ma.us).*

### Additional Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- (E) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

### Maximum Contaminant Level Goal or MCLG

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The North Raynham Water District is responsible for providing high quality water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking water hotline or at

<http://www.epa.gov/safewater/lead>. In order to ensure that tap water is safe to drink, EPA prescribes regulations to establish limits for contaminants in bottled water which must provide the same protection for public health. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Some people who use water-containing chlorine well in excess of the MRDL could experience irritating effects to their eyes, nose and could experience stomach discomfort.

There are also sources of contamination that exist from physical piping connections in the water supply system between potable and non-potable sources. The District is required by the State to maintain a program to eliminate all physical piping cross-connections in municipal, industrial and commercial establishments by the use and proper maintenance of backflow prevention devices. However, the law does not address residential cross-connections of which there are many. Residents should be aware of the hazards of any cross-connections between potable and non-potable sources that provide for the non-potable source to be siphoned back into the District's water system (potable source). This occurs when the water pressure in the water supply suddenly drops due to a fire or water main break and permits a contaminated source to flow back into the water piping. Common sources of residential cross-connections are filling of swimming pools and car wash buckets filled with soap that both have the hose submerged in the water. The best protection against any cross-connections is to provide an air gap between the source and the receptor.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791).



The Board of Water Commissioners meets on a monthly basis. Please call the District office at (508) 824-0520 to find out the time for the next scheduled meeting. The meeting times are also posted at the water office located at 80 Baker Road and the Raynham Town Hall located at 558 South Main Street, Raynham.